

Level 1 Validation Certificate

W S O

This document verifies that the Level 1 Validation process was completed. The session details and audit review outcomes are included here.

This certificate is required for submission – alongside the Level 1 validated water audit software file – to the California Department of Water Resources.

Call Date: 9/23/2019

Water Supplier

| | |
|------------------------|--|
| Supplier Name: | Hi-Desert Water District |
| Supplier Participants: | Cheri Nutter, Kami Zimmerman, Marty Stockstell, Glenn Ware |

Key Audit Metrics

| | | |
|---|-------|------------------|
| Data Validity Score: | 55 | |
| ILI: | 1.10 | |
| Real Loss: | 27.67 | gal / conn / day |
| Apparent Loss: | 7.38 | gal / conn / day |
| Non-Revenue Water as Percent of Cost of Operating System: | 2.3% | |

Validator

| | |
|---------------------------|---|
| Validator: | Colin Stief Water Systems Optimization |
| Validator Qualifications: | Water Audit Validator Certificate from the AWWA California Nevada Section |

Certification Statement by Validator

This water loss audit report has been Level 1 validated per the requirements of California Code of Regulations Title 23, Division 2, Chapter 7 and the California Water Code Section 10608.34.

All recommendations on volume derivation and Data Validity Grades were incorporated into the water audit. ☒

Level 1 Validation – Water Supplier Confirmation

This document confirms participation in and endorsement of the Level 1 Validation as completed.

This acknowledgement is required for submission – alongside your Level 1 validated water audit software file – to the California Department of Water Resources.

Water Supplier Name: Hi-Desert Water District

Water Supplier Public Water System ID: 3610073

Water Audit Period: Calendar 2018

Water Audit & Water Loss Improvement Steps

Steps taken in the audit period timeframe to increase data source accuracy, reduce real losses, and/or reduce apparent losses, as informed by the water audit.

Continued to replace old water mains and out dated water meters. Standardize record keeping and data collection.


Certification Statement by Water Supplier Executive:

This water loss audit report meets the requirements of California Code of Regulations Title 23, Division 2, Chapter 7 and the California Water Code Section 10608.34 and has been prepared in accordance with the method adopted by the American Water Works Association, as contained in their manual, *Water Audits and Loss Control Programs, Manual M36, Fourth Edition* and in the Free Water Audit Software version 5.

Executive Name (print): Tony Culver

Executive Position: Interim General Manager

Signature:



Date: 9/26/2019